



Product Service

CERTIFICATE

No. B 004850 0002 Rev. 00

Holder of Certificate: Shanghai Kuka Special Cable Co., Ltd.

Room 4103, Building 2
NO. 383, Huancheng east Rd
Fengxian
201400 Shanghai
PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): 004778
Certification Mark:



Product: Plastic insulated cables
Cable for use in photovoltaic systems

Model(s): H1Z2Z2-K 1×1.5 mm², 1×2.5 mm², 1×4 mm²,
1×6 mm², 1×10 mm², 1×16mm², 1×25 mm²,
1×35 mm².

Parameters:

Rated Voltage:	DC 1500V (between conductors and between conductor and earth) AC U ₀ /U: 1,0/1,0 kV
Application Class:	A
Protection Class:	II
Ambient Temperature:	-40°C~ + 90°C
Max. Temperature at conductor:	120°C

Tested according to: EN 50618:2014

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 701261910401-00

Valid until: 2024-06-16

Date, 2019-11-04

(Yaqun Alex Liu)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT